



Estd : 1947

Walchand College of Engineering

(Government-Aided Autonomous Institute)

Vishrambag, SANGLI - 416415 (M.S.) India

Website : www.walchandsangli.ac.in

Email : wce@walchandsangli.ac.in, director@walchandsangli.ac.in

☎ Director - +91-233-2303433

☎ Office - +91-233-2303115

Fax : +91-233-2300831

Ref. No.: -WCE/CIVIL/TEL/Testing/2020-21/159-160/ 701

Date: - 04/11/2020

To,
M/s. Siddheswar Cement Articles,
L.K.Akiwate No.315/3,Plot No.1
Ind.Estate, Shirol road Jaysingpur,
Tal-Shirol, Dist.- Kolhapur.

Subject: - With reference to your letter dt. 21.10.2020 and 31.10.2020 testing of Cement Concrete Cube, specimens supplied by you.

Name of work: Not Mentioned

Name of Contractor: - M/s. Siddheswar Cement Articles,

Dear Sir,

With reference to your letter mentioned above, we have carried out testing of Cement Concrete Cube, Specimens supplied by you. The test report of the materials is attached herewith for your kind reference.

NOTE:

The information given above is true and correct to the best of our knowledge. The college is responsible only for the technical aspects of the work carried out under the scope of the request of the client. The college or its representative will not be party to legal implications arising out of use of this report in any manner.

** Subject to Sangli jurisdiction.



Director

Ref. No.: -WCE/CIVIL/TEL/Testing/2020-21/160/

Date: - 04/11/2020

Name of work: Not Mentioned

Name of Contractor: - M/s. Siddheswar Cement Articles,

TEST REPORT

Sr. No.	Grade of Concrete	Date of Casting	Days of Curing	Comp. Strength (MPa)	Av. Comp. Strength (MPa)
1	Concrete Cover Block (100 X 100)	04.10.2020	28	62.00	64.00
				63.00	
				67.00	


NOTE:

The information given above is true and correct to the best of our knowledge. The college is responsible only for the technical aspects of the work carried out under the scope of the request of the client. The college or its representative will not be party to legal implications arising out of use of this report in any manner.

** Subject to Sangli jurisdiction.



Mr. A. K. Mali
In-Charge Transportation Lab.



Dr. S. N. Tande
HoD (Civil)

Ref. No.: -WCE/CIVIL/TEL/Testing/2020-21/159/

Date: - 04/11/2020

Name of work: Not Mentioned

Name of Contractor: - M/s. Siddheswar Cement Articles,

TEST REPORT

Sr. No.	Grade of Concrete	Date of Casting	Days of Curing	Comp. Strength (MPa)	Av. Comp. Strength (MPa)
1	Concrete Cover Block (100 X 100)	04.10.2020	21	48.00	51.67
				51.00	
				56.00	


NOTE:

The information given above is true and correct to the best of our knowledge. The college is responsible only for the technical aspects of the work carried out under the scope of the request of the client. The college or its representative will not be party to legal implications arising out of use of this report in any manner.

** Subject to Sangli jurisdiction.



Mr. A. K. Mali
In-Charge Transportation Lab.



Dr. S. N. Tande
HoD (Civil)